



# CITY OF ELY

---

501 Mill Street Ely, Nevada 89301  
City Hall (775) 289-2430 - Fax (775) 289-1463

**Date:** February 5, 2019

**To:** Mayor Van Camp  
City Council Members  
Utility Board Members

**From:** Bruce Ashby - WWTP Leadman

**Subject:** Monthly Report – **January Waste Water Plant and Lab**

During the month of January, performed weekly tasks of lubrication of blowers and cleaning of air filters. Adjusted drive chain on clarifier and changed oil in Roto screen drive gear boxes. Worked throughout the month with Shannan on S.O.P. of Plant operation and general maintenance. Ran 20 coliform test samples for Shannan to analyze to familiarize her with present/absent in water samples. Gust Electric ordered motor savers to be installed on United blower, still waiting for parts.

Throughout the month, the Lab analyzed 51 coliform samples.