



# CITY OF ELY

---

501 Mill Street Ely, Nevada 89301  
City Hall (775) 289-2430  
Fax (775) 289-1463

**To: Mayor Robertson  
Ely City Council Members**

**From: Carl Siemer – Water/Sewer Leadman**

**Subject: Monthly Report September 2020**

## **Water Digs:**

- Main break on 10<sup>th</sup> and Avenue G - Pipe was cracked all the way around, probably from ground shifting.
- #4 Conners Court - Curb stop valve broke. We replaced the old rusted water line with poly pipe and also installed a meter pit.
- 890 Avenue D - Repaired service line. This line was poly pipe. We found that it had a cut on it. Probably happened during installation years ago. We spliced in a new piece.

## **Sewer Lines:**

- 1198 Avenue G – This line was rodded on our side with no blockage. It was determined that the blockage was on their side.
- 316 Nevada Avenue – This line was rodded. It was determined the blockage was on their side.
- 10<sup>th</sup> and 11<sup>th</sup> street off Avenue D -Sent camera down and cleaned the city sewer line to look into a citizen complaint.
- 1270 Avenue L– This line was rodded. It was determined the blockage was on their side.
- 9<sup>th</sup> & Avenue H – Pulled out a small amount of roots.
- State Patrol - Pulled out a small amount of roots.
- 937 Avenue C – Pulled out a small amount of roots. Also what looked like rags and plastic bags.

## **Miscellaneous:**

- Quarterly Pumpage Report completed and sent to the State.
- 1 Non-Payment shut-off.

The City of Ely is an equal opportunity provider and employer.

- Monthly Coliform samples are completed.

**Wells:**

- RW-7: Is down at this time. My understanding is they are having a spinner test done and replacing the pump and motor. The mine is saying it will be completed October 15<sup>th</sup>. At that time we will be flushing and taking water samples. When all water samples have passed, we will be returning this well back into our system.
- 17 & M: Well pump still in auto (1,400 GPM).
- 10 & M: Well pump still in auto (900 – 1,000 GPM)
- Golf Course Well: Currently pumping 700 – 800 GPM.
- North Street Well: Currently pumping 600 - 700 GPM.
- The Terrace Well: Pump and motor have been replaced. Well has been flushed and water samples taken and passed. This well is ready to put back into our system if needed.

**Aultman Project:**

- Locates going on as needed for this project.

**Employee Status:**

Full crew.